

ANSI/ISEA 113-20xx

Revision of ANSI/ISEA 113-2008

**American National Standard for
Fixed and Portable Decontamination Shower Units**

Secretariat

International Safety Equipment Association

Approved

American National Standards Institute, Inc.

For ISEA use only - do not distribute

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether they have approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review and users are cautioned to obtain the latest editions.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no persons shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by

**International Safety Equipment Association
1901 North Moore Street, Suite 808, Arlington, Virginia 22209**

Copyright by ISEA

All rights reserved.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America

Foreword (This Foreword is not part of American National Standard ANSI/ISEA 113-) Since the devastating 9-11 attacks on the USA, portable hazmat decontamination shower systems of all types have appeared in the North American marketplace - from homemade plastic and saw horse showers to single user pneumatic and metal framed shower units and multiple line 3- and 4- stage mass casualty shower systems. While most products were well-intentioned, no actual standard in terms of flow rates, water stream, shower head placement, and other pertinent performance characteristics existed prior to the development of this standard.

This second edition of ANSI/ISEA 113 incorporates minor changes in an effort to clarify the testing procedures for decontamination shower equipment. The minimum performance requirements for such equipment has not changed. The standard was prepared by the Emergency Eyewash and Shower Group of the International Safety Equipment Association, whose members are thoroughly knowledgeable in the design, set up, and use of this important safety equipment. Current members of the Group include: Bradley Corporation, Encon Safety Products, FSI North America®, Guardian Equipment, Honeywell Safety Products, Prevor, Inc., Sellstrom Manufacturing Company, Speakman Company, Therm-Omega-Tech and VisionAid.

In addition, valuable outside comments and assistance was sought and offered by various end users in emergency management, fire, state and federal agencies, hospitals, and industry from across North America.

This standard is not meant nor designed to offer direction to professionally trained first responders in how these shower systems shall be deployed or placed at a scene. It is also important to note that this standard does not address the shower duration for a victim. The incident commander or other person overseeing the situation must determine the length of decontamination taking into consideration the contaminants involved, equipment availability, weather conditions and other influencing factors.

Training in the care, use, and maintenance of all portable hazmat decontamination shower systems should be followed in accordance with the actual manufacturer's instructions.

Although not specifically addressed in this standard, consideration should also be given to the proper disposal of waste flushing fluids after use. The use of waste pumps and bladder tanks to pump out and hold the 'dirty water' for removal to an authorized disposal site, along with outside environmental conditions are some but not all of the considerations. Always consult local, state, and federal regulations that may apply.

Suggestions for the improvement of this standard are welcome. They should be sent to the ISEA, 1901 N. Moore Street, Suite 808, Arlington, VA 22209.

This standard was processed and approved using consensus procedures prescribed by the American National Standards Institute. The following organizations were contacted prior to the approval of this standard. Inclusion in this list does not necessarily imply that the organization concurred with the submittal of the proposed standard to ANSI.

Contents

1. Scope..... 1

2. Purpose 1

3. Compliance..... 1

4. Definitions 1

5. Performance and Testing Criteria for Fixed and Portable Decontamination Shower Units..... 1

 5.1 Performance Criteria for Fixed Decontamination Shower Units..... 1

 5.2 Testing Procedures for Fixed Decontamination Shower Units..... 2

 5.3 Performance Criteria for Portable Decontamination Shower Units..... 2

 5.4 Testing Procedures for Portable Decontamination Shower Units..... 2

 5.5 Performance of Control Valves..... 3

6. Maintenance, Care, Training and Storage 3

APPENDIX 4

For ISEA use only - do not distribute

American National Standard for Fixed and Portable Decontamination Shower Units

1. Scope

This standard is intended for use by first responders and receiving medical facilities for initial decontamination of victims of exposure. This standard addresses classification and testing criteria for fixed and portable showers designed for decontamination facilities. The standard establishes performance for equipment capable of decontaminating one or more persons at the same time.

2. Purpose

This standard is intended to provide uniform minimum requirements for the performance, use, maintenance and training for fixed and portable decontamination showers.

3. Compliance

Manufacturers shall certify that the shower unit complies with the requirements of this standard, and can label products that comply with the requirements of this standard.

4. Definitions

certify: Verify through conformity assessment evaluation that a product complies with the requirements of this standard. The evaluation must be based on product testing to verify performance requirements. Testing may be performed by an independent third-party laboratory or by the manufacturer.

fixed decontamination shower unit: Primary decontamination device not intended to be portable, which is normally permanently installed to an existing flushing fluid supply.

flushing fluid: Potable water, preserved water, preserved buffered saline solution or other medically acceptable solution manufactured and

labeled in accordance with applicable government regulations. (See Appendix A3, A4).

portable decontamination shower unit: Primary decontamination device normally intended for temporary installation, which can be transported to the site of use.

multiple-user unit: Device designed and intended for use by two or more individuals simultaneously.

potable water: Water that is suitable for drinking.

shower station: Decontamination device within a multiple-user unit that is intended for use by one person.

single user-unit: Device designed and intended for use by a single individual at a time.

tepid: A flushing fluid temperature conducive to promoting decontamination. A suitable range is 16 – 38° C (60 - 100 ° F).

5. Performance and Testing Criteria for Fixed and Portable Decontamination Shower Units

5.1 Performance Criteria for Fixed Decontamination Shower Units

5.1.1 A means shall be provided to ensure that a controlled flow of flushing fluid is provided at a velocity low enough to be non-injurious to the user.

5.1.2 Fixed decontamination shower units shall be constructed of materials that will not corrode in the presence of the flushing fluid or corrosive materials with which they may come in contact during normal use.

5.1.3 Fixed decontamination shower units shall deliver flushing fluid a minimum of 75.7 liters per minute (20 gpm) per shower station. If shut off valves are installed in the supply line for

maintenance purposes, provisions shall be made to prevent unauthorized shut off.

5.1.4 Manufacturer's instructions shall provide information on the effective spray pattern for their products within the minimum specified flow criteria. The center of the spray pattern shall be located at least 40.6 cm (16 in.) from any obstruction. The flushing fluid shall be dispersed throughout the pattern effectively drenching the entire body.

5.1.5 Fixed decontamination shower units shall be capable of meeting performance criteria at operating pressures of 206.8 kPa to 620.5 kPa (30 to 90 psi) at the point of discharge

5.1.6 Fixed decontamination shower units shall be installed to deliver tepid flushing fluid

5.2 Testing Procedures for Fixed Decontamination Shower Units

Fixed decontamination shower units shall be certified as follows:

- (1) Connect a flow meter to the shower unit to be tested, or provide other means of measuring flushing fluid flow.
- (2) Connect the shower per the manufacturer's specifications to a flushing fluid supply at a flow pressure of 310.3 ± 13.8 kPa (45 ± 2 psi).
- (3) Open the valves to all shower stations in the shower unit and verify that they stay open.
- (4) Determine that flushing fluid is substantially dispersed throughout the pattern. Verify that the flow rate is a minimum of 75.7 liters per minute (20 gpm) from each shower station simultaneously.

5.3 Performance Criteria for Portable Decontamination Shower Units

5.3.1. Portable shower units shall be constructed in such a manner that they can continue to operate as designed when configured with all supporting accessory items (i.e., air heaters, air coolers, water heaters) when exposed to environmental elements such as high wind speeds and high and low extreme temperatures, all as specified by the

manufacturer. A dual means shall be provided for securing portable shower units to the ground.

5.3.2 A means shall be provided to ensure that a controlled flow of flushing fluid is provided at a velocity low enough to be non-injurious to the user.

5.3.3 Portable shower units shall be capable of delivering flushing fluid at a minimum of 9.4 liters per minute (2.5 gpm) per shower station with no obstructions between the user and the showering fluid.

5.3.4 Manufacturers' instructions shall provide information on the effective spray pattern for their products within the minimum specified flow criteria. At a minimum, all installed spray nozzle heads shall be deployed such that the entire body is thoroughly drenched over the shower period. If multiple shower heads are used, the topmost shower head shall be a minimum of 182.3 cm (72 in.) above the shower floor level to allow the entire head area to be easily showered. Subsequent shower heads shall be at approximately 121.9 cm (48 in.) above the shower floor for decontamination of the chest and back area; and at approximately 76.2 cm (30 in.) above the shower floor area for decontamination of the lower body, legs and feet.

All hanging trigger type guns with shutoffs shall have a minimum 5 foot length hose such that the user can effectively reach and decontaminate either their own entire body or such that the first responder can properly decontaminate an entire body of a victim on a stretcher on a conveyor in the shower area.

5.3.5 Portable shower units shall meet the performance criteria at operating pressures of 310.3 to 517.1 kPa (45 to 75 psi) at the point of discharge.

5.3.6 Portable shower units shall be capable of using tepid flushing fluid. Tepid flushing fluid shall be used whenever practical.

5.4 Testing Procedures for Portable Decontamination Shower Units

Portable decontamination shower units shall be certified as follows:

(1) Connect a flow meter to the shower unit to be tested, or provide other means of measuring flushing fluid flow.

(2) Connect the shower per the manufacturer's specifications to a flushing fluid supply at a flow pressure of 310.3 ± 13.8 kPa (45 ± 2 psi).

(3) Open the valves to all shower stations in the shower unit and verify that they stay open.

(4) Determine that flushing fluid is substantially dispersed throughout the pattern. Verify that the flow rate is a minimum of 9.4 liters per minute (2.5 gpm) from each shower station simultaneously.

5.5 Performance of Control Valves

The valve shall go from "off" to "fully-opened" in 1 second or less. The valve shall be resistant to corrosion. Manual or automatic actuators shall be easy to locate and readily accessible to the user.

6. Maintenance, Care, Training and Storage

6.1 Manufacturers shall provide deployment, operation, inspection and maintenance instructions with decontamination equipment and accessories. Instructions for all decontamination equipment shall be readily accessible to maintenance and inspection personnel.

6.2 Fixed shower units shall be activated weekly for a period long enough to verify operation and ensure that flushing fluid is available.

6.3 Portable shower units shall be deployed every 3 months to ensure proper operation.

6.4 Where the possibility of freezing conditions, and/or high humidity or heat exists, adequate protection and storage of all equipment shall be utilized. Consult manufacturers for instructions.

6.5 Any worker required to set up or operate decontamination showers shall be instructed in the location and proper use and care of the equipment.

For ISEA use only

Appendix

This appendix is not part of American National Standard ANSI/ISEA 113-20xx, but is included for information only.

A1. Delivered Flushing Fluid Temperature

Continuous and timely irrigation of affected tissues for the recommended irrigation period are the principal factors in providing first aid treatment. Providing flushing fluid at temperatures conducive to use for the recommended irrigation period is considered an integral part of providing suitable facilities. Medical recommendations suggest a flushing fluid at tepid temperatures be delivered to affected chemically-injured tissue. Temperatures in excess of 38°C (100°F) have proven to be harmful to the eyes and can enhance chemical interaction with the eyes and skin.

While cold flushing fluid temperatures provide immediate cooling after chemical contact, prolonged exposure to cold fluids affect the ability to maintain adequate body temperature and can result in the premature cessation of first aid treatment. Recent information indicates that a temperature of 16°C (60°F) is suitable for the lower parameter for tepid flushing fluid without causing hypothermia to the equipment user.

A2. Containment

While it is recognized that there are environmental issues associated with the run-off and containment of any flushing fluid that becomes contaminated when treating a victim, such procedures should be established in consultation with authorities and applicable local, state and federal regulations. Several published resources are available including:

- *NFPA Supplement 10, Guidelines for Decontamination of Fire Fighters and Their Equipment Following Hazardous Materials Incidents* Pg.14,, National Fire Protection Association, 1997
- *Rapid Access Mass Decontamination Protocol*, The Capitol Region Metropolitan Medical Response System, Hartford, CT, January, 2003
- Comprehensive Environmental Response, Compensation and Liability Act of 1980, 42 U.S.C § 9601 et seq. (2006)

A3. Alternative Decontamination Solutions and Systems

If alternative decontamination solutions or systems are utilized, appropriate volumes and/or flow pressure rates should be used to obtain effective decontamination. Performance should meet manufacturers' specifications with applications to personnel based on Sections 5.1.4 and 5.3.4 such that the entire body of the victim is thoroughly decontaminated.

A4. Flushing Fluid Quality for Portable Units

For portable systems designed to utilize water, ideally potable water should be used. However, it is recognized that there may be situations where potable water is not readily available. When this is the case, any acceptable and available flushing fluid may be used.

A5. Removal of Decontaminated Clothing

Where possible and feasible portable decontamination showers should be supplied to provide private undress, shower, rinse, redress areas per victim. It is further understood that all victims should remove all contaminated clothing prior to showering if at all feasible and store/dispose of said clothing in sealed containers such as over pack drums. All first responders dressed in sealed Level A type chemical suit

clothing should decontaminate the entire suit during the decontamination process prior to chemical suit removal. Additional information related to acceptable decontamination protocols are available from numerous resources including:

- OSHA Best Practices for Hospital-Based First Receivers of Victims from Mass Casualty Incidents Involving the Release of Hazardous Substances, January 2005
- Guidelines for Mass Casualty Decontamination During a Terrorist Chemical Agent Incident (prepared by U.S. Army Soldier & Biological Chemical Command), January 2000
- Guidelines for Cold Weather Mass Casualty Decontamination During a Terrorist Chemical Agent Incident (prepared by U.S. Army Soldier & Biological Chemical Command), January 2002

For ISEA use only - do not distribute